



FLOODPLAIN INFORMATION
 A PORTION OF THE PROPERTY SHOWN HEREON LIES IN A FLOOD PRONE AREA ACCORDING TO (FIRM) FLOOD INSURANCE RATE MAP FOR JEFFERSON COUNTY, KENTUCKY. SAID AREA IS SHOWN ON MAP #21111C0054E, WITH AN EFFECTIVE DATE OF DECEMBER 5, 2006.

PROPOSED LOT 3
 +/- 1,134,302 SQ. FT.
 +/- 26.04 AC

- *MSD NOTES:**
1. ONSITE DETENTION WILL BE PROVIDED. POST-DEVELOPED PEAK FLOWS WILL BE LIMITED TO PRE-DEVELOPED PEAK FLOWS FOR THE 2, 10, 25 AND 100-YEAR STORMS OR TO THE CAPACITY OF THE DOWNSTREAM SYSTEM, WHICHEVER IS MOST RESTRICTIVE. CAPACITY SHALL BE VERIFIED TO THE DOWNSTREAM SIDE OF EITHER THE RAILROAD CROSSING OR TO THE DOWNSTREAM SIDE OF THE CULVERT UNDER LEES LANE FOR THE EAST DETENTION BASIN AND THE DOWNSTREAM SIDE OF THE CULVERT UNDER THE RAILROAD TRACKS FOR THE WEST DETENTION BASIN. THE EXISTING C FACTOR SHALL REFLECT THE EXISTING ONSITE STORAGE VOLUME FOR THE PREDEVELOPED CONDITION. ADDITIONAL INFORMATION MAY BE REQUIRED PRIOR TO MSD CONSTRUCTION PLAN APPROVAL.
 2. AN MSD DRAINAGE BOND WILL BE REQUIRED.
 3. IS SITE HAS ANY PASS-THRU DRAINAGE, AN EASEMENT PLAT WILL BE REQUIRED PRIOR TO MSD GRANTING CONSTRUCTION PLAN APPROVAL.
 4. NO PUBLIC SEWERS AVAILABLE. BOARD OF HEALTH APPROVAL REQUIRED TO MSD CONSTRUCTION PLAN APPROVAL. PRELIMINARY PLAN APPROVAL FROM BOARD OF HEALTH REQUIRED PRIOR TO MSD APPROVAL.
 5. ACOE APPROVAL MAY BE REQUIRED PRIOR TO MSD CONSTRUCTION PLAN APPROVAL.
 6. THE FINAL DESIGN OF THIS PROJECT MUST MEET ALL MS4 WATER QUALITY REGULATIONS ESTABLISHED BY MSD. SITE LAYOUT MAY CHANGE AT THE DESIGN PHASE DUE TO PROPER SIZING OF GREEN BEST MGMT. PRACTICES.
 7. AN EPSC PLAN SHALL BE DEVELOPED AND APPROVED IN ACCORDANCE WITH MSD DESIGN MANUAL AND STANDARD SPECIFICATIONS PRIOR TO CONSTRUCTION PLAN APPROVAL.

PROPOSED LOT 1
CURRENT ZONING: M-3/EZ-1
PROPOSED ZONING: M-3/EZ-2
FORM DISTRICT: SUBURBAN WORKPLACE
CURRENT ADDRESS:
6001 CAMPGROUND RD.
38.34 ACRES

PARCEL OWNER, ADDRESS, AND SOURCE OF TITLE
 ATKEMIX TEN, INC.
 6200 CAMPGROUND ROAD
 LOUISVILLE, KY 40216
 DEED BOOK 6886 PAGE 419

LINE	BEARING	DISTANCE
L2	N 55°53'51" E	100.40'
L3	N 50°07'44" E	100.08'
L4	S 44°32'26" W	100.52'
L5	N 50°08'41" E	161.81'
L9	N 59°36'31" W	33.16'
L10	S 41°42'09" W	101.77'

TREE CANOPY	
LOT AREA	1,669,882 SF
EXISTING TREE CANOPY	1,603,086 SF (96.0% OF ENTIRE SITE)
REQUIRED TREE CANOPY PRESERVED	333,9763 SF (20.0% OF ENTIRE SITE)
PROPOSED TREE CANOPY PRESERVED	349,308 SF (21.8% OF ENTIRE SITE)
INTERIOR LANDSCAPING	
TOTAL PROPOSED VUA	460,562 SF
I.A. REQUIRED	34,549 SF (7.5%)
I.A. PROVIDED	35,499 SF (7.7%)
TREES REQUIRED	178 TREES

BENCHMARK DATA:

➤ BENCHMARK 1
 1" IRON PIN W/ 1" PLASTIC CAP STAMPED "ACES CONTROL" LOCATED IN THE NORTH R/W OF CAMPGROUND ROAD
 N: 258297.08
 E: 1177462.37
 KY SPC (NORTH)
 ELEV: 446.58

➤ BENCHMARK 2
 1" IRON PIN W/ 1" PLASTIC CAP STAMPED "CROWE PLS 2957" LOCATED IN THE SOUTHERN MOST PROPERTY CORNER
 N: 256030.57
 E: 1177575.88
 KY SPC (NORTH)
 ELEV: 444.08

COPYRIGHTS AND DISCLAIMERS

THE COPYRIGHTS TO ALL DESIGNS AND DRAWINGS ARE THE PROPERTY OF ACES. REPRODUCTION OR USE FOR ANY PURPOSE OTHER THAN THAT AUTHORIZED BY ACES IS FORBIDDEN.

ACES ASSUMES NO RESPONSIBILITY FOR DATA SUPPLIED IN AN ELECTRONIC FORMAT. DATA IS PROVIDED ELECTRONICALLY AS A CONVENIENCE AND THE RECIPIENT IS RESPONSIBLE FOR VERIFYING ACCURACY TO THE HARD COPY OF THE CURRENT DESIGN DRAWINGS WHICH HAVE BEEN SEALED AND SIGNED. IN THE EVENT OF INCONSISTENCIES BETWEEN THE ELECTRONIC AND THE HARD COPY DATA, THE RECIPIENT IS RESPONSIBLE FOR OBTAINING CLARIFICATION ON WHICH PREVAILS.

THE RECIPIENT RELEASES ACES, ITS EMPLOYEES, CONSULTANTS AND AGENTS FROM ANY AND ALL CLAIMS ARISING IN ANY WAY FROM THE CONTENT OR PROVISION OF THE ELECTRONIC DATA.

NOTHING SHALL REDUCE OR DIMINISH ACES'S OWNERSHIP OF OR COPYRIGHT IN THE DATA OR ITS COMPILATION OR ARRANGEMENT. ANY ANALYSIS, SOFTWARE OR FORMATTING IN THE ELECTRONIC DATA IS CONSIDERED PROPERTY OF ACES.

THE RECIPIENT OF ELECTRONIC DATA IS PROHIBITED FROM REDISTRIBUTING OR USING ANY DESIGN OR DRAWING INFORMATION WITHIN THE FILES FOR ANY REASON OTHER THAN IT WAS ORIGINALLY DESIGNED WITHOUT THE WRITTEN CONSENT OF ACES.

DEVELOPER'S NAME & ADDRESS
REALITY LINK
 201 RIVERPLACE SUITE 400
 GREENVILLE, SC 29601
 CONTACT: JAMES McCADEN

LEGEND

○	1/2" IRON PIN W/ 1" PLASTIC CAP STAMPED	---	PROPERTY LINE
●	CONCRETE R/W MONUMENT	---	SETBACK LINE
○	IRON PIN FOUND	---	EASEMENTS
○	IRON PIN SET	---	LOT LINE TO BE ABANDONED
○	SANITARY SEWER MANHOLE	---	CENTERLINE
○	SANITARY SEWER CLEAN OUT	---	GAS LINE
○	ANCHOR	---	OVERHEAD UTILITIES
○	UTILITY POLE	---	BURIED TELEPHONE
○	ELECTRIC BOX	---	SANITARY SEWER LINE
○	ELECTRIC METER	---	WATER LINE
○	GAS VALVE	---	STORM SEWER LINE
○	WATER VALVE	---	FENCE LINE
○	FIRE HYDRANT	---	DRAINAGE ARROW
○	GAS METER	---	- INGRESS/EGRESS EASEMENT
○	TELEPHONE PEDESTAL	---	- WETLANDS AREA W/BUFFER
○	STORM SEWER MANHOLE	---	TCCA AREAS
○	BUILDING SET BACK LINE	---	- DRAINAGE EASEMENT

DEVELOPMENT SUMMARY

STATISTIC	PERMITTED / REQUIREMENT	PROVIDED
CURRENT ZONING	M-3, EZ-1	M-3, EZ-1
PARCEL NUMBER		101204560000
FORM DISTRICT	SUBURBAN WORKPLACE FORM DISTRICT	SUBURBAN WORKPLACE FORM DISTRICT
EXISTING USE	VACANT	VACANT
PROPOSED USE	WAREHOUSING/DISTRIBUTION	WAREHOUSING/DISTRIBUTION
TOTAL SITE AREA	N/A	38.34 +/- AC (1,670,148 +/- S.F.)
IMPERVIOUS AREA	EXISTING: 0%	PROPOSED: 18.48 (48.2%)
BUILDING SETBACKS	FRONT: 25' SIDE: 0' REAR: 0'	FRONT (CAMPGROUND RD): 433.6' SIDE (NORTHEAST): 99.23' SIDE (SOUTHWEST): 190' REAR: 432.6'
TOTAL PARKING	MINIMUM: 127 SPACES 1 SPACE PER 2000 SF OF BUILDING MAXIMUM: 507 SPACES 1 SPACE PER 500 SF OF BUILDING	2 ADA SPACES PROVIDED 27 STANDARD SPACES PROVIDED 29 TOTAL SPACES PROVIDED

DEVELOPMENT SUMMARY

STATISTIC	PERMITTED / REQUIREMENT	PROVIDED
F.A.R.	MAXIMUM: 4.0	0.15
BUILDING AREA	N/A	TOTAL: 253,500 S.F.
BUILDING HEIGHT	50'	37'-4"
INTERIOR VUA	7.5% > 30,000 SF	8.3%
461,936 SF	34,645 SF	38,285 SF

- *NOTES:**
1. CONSTRUCTION PLANS, BOND AND PERMIT ARE REQUIRED BY METRO PUBLIC WORKS (MPW) PRIOR TO CONSTRUCTION APPROVAL FOR ALL WORK WITHIN RIGHT OF WAY.
 2. SIDEWALK RECONSTRUCTION AND REPAIRS SHALL BE REQUIRED, AS NECESSARY, TO MEET CURRENT MPW STANDARDS AND SHALL BE INSPECTED PRIOR TO FINAL BOND RELEASE.
 3. ALL NEW AND EXISTING SIDEWALKS SHALL BE BROUGHT UP OR BUILT TO CURRENT ADA STANDARDS.
 4. MITIGATION MEASURES FOR DUST CONTROL SHALL BE IN PLACE DURING CONSTRUCTION TO PREVENT FUGITIVE PARTICULATE EMISSION FROM REACHING EXISTING ROADS AND NEIGHBORING PROPERTIES.
 5. MOSQUITO CONTROL IN ACCORDANCE WITH CHAPTER 96 OF LOUISVILLE JEFFERSON COUNTY METRO ORDINANCE MUST BE MAINTAINED.
 6. ALL CONSTRUCTION AND SALES TRAILERS MUST BE PERMITTED BY THE DEPT. OF PUBLIC HEALTH & WELLNESS IN ACCORDANCE WITH CHAPTER 115 OF LOUISVILLE JEFFERSON COUNTY METRO ORDINANCE.
 7. OFF-STREET LOADING AND REFUSE COLLECTION AREAS SHALL BE LOCATED AND SCREENED SO AS NOT TO BE VISIBLE FROM ADJACENT PUBLIC STREETS AND RESIDENTIAL USES.
 8. ACCESSORY STRUCTURES SHALL BE IN COMPLIANCE WITH SECTIONS 5.5.5 AND 10.2.6 OF THE LOUISVILLE METRO LAND DEVELOPMENT CODE.
 9. CONSTRUCTION PLANS AND DOCUMENTS SHALL COMPLY WITH LOUISVILLE AND JEFFERSON COUNTY METROPOLITAN SEWER DISTRICT'S DESIGN MANUAL AND STANDARD SPECIFICATIONS AND OTHER LOCAL, STATE AND FEDERAL ORDINANCES.
 10. OUTDOOR AMENITY AREA SHALL PROVIDE SEATING NOT LESS THAN 1 SEAT PER 200 SQ. FT. OF AMENITY SPACE. AT LEAST 25% OF THE SPACE SHALL BE SHADED OR LANDSCAPED. FINAL DESIGN TO BE SHOWN ON THE APPROVED LANDSCAPE PLAN AND COMPLIANT WITH LAND DEVELOPMENT CODE SECTION 5.12.2.

WAIVERS REQUIRED:

1. PARKING WAIVER IS BEING REQUESTED TO REDUCE THE REQUIRED PARKING FROM 127 SPACES TO 29 SPACES.

2. WAIVER IS BEING REQUESTED FROM SECTION 5.9.2.A.1.b.i FOR PEDESTRIAN CONNECTION TO CAMPGROUND ROAD. DUE TO WETLANDS AND TREE PRESERVATION AREAS. FEE IN LIEU HAS BEEN APPROVED FOR SIDEWALKS ALONG CAMPGROUND AND THEREFORE THERE IS NO PEDESTRIAN CONNECTION TO TIE INTO.

STORMWATER MANAGEMENT INFORMATION

PRE-DEVELOPED	POST-DEVELOPED
WATERSHED #1 COMPOSITE CURVE NUMBER: 73 IMPERVIOUS AREA: 0.0 ACRES	WATERSHED #1 COMPOSITE CURVE NUMBER: 92 IMPERVIOUS AREA: 14.45 ACRES
WATERSHED #2 COMPOSITE CURVE NUMBER: 73 IMPERVIOUS AREA: 0.0 ACRES	WATERSHED #2 COMPOSITE CURVE NUMBER: 89 IMPERVIOUS AREA: 6.29 ACRES

REVISIONS

NO.	DATE	DESCRIPTION


REALITY LINK
 6001 CAMPGROUND ROAD
 LOUISVILLE, KY 40216

ACES
 ARNOLD CONSULTING
 ENGINEERING SERVICES, INC.
 P.O. BOX 4388
 BOWLING GREEN, KY 42101
 PHONE: (270) 780-9445

JOB NUMBER:
 DATE: 6-10-2021
 SCALE: 1" = 100'
 DRAWN: B. McDANIEL
 CHECKED: B. ZACKERY
 FILE PATH:
 2:SIT/DEV/DEV-DEVELOPMENT PLAN



DDP
 DISTRICT
 DEVELOPMENT
 PLAN



WM #12242