



# Jefferson County Fire Inspectors Association

---

410 S Fifth Street, Ste. 141  
Louisville, Ky. 40202  
502-572-3597



## LMCO 94.80 (A) Statement

05.02.24

Updates in 2023 aligned LMCO Chapter 94: Fire Prevention requirements with 815 KAR 10:060, the Kentucky Standards of Safety, designed to supplement the Kentucky Building Code. 815 KAR 7:120, in matters of fire safety. This document excludes conditions in which the methods of construction met the uniform state building code requirements, as applicable, at the time of construction.

Specifically, 94.80(A) identifies the clear width of a roadway as 20 feet. It is the consensus of Fire Departments in Jefferson County that this requirement applies to all new construction projects moving forward. It is not intended to require that any existing roadway that is less than 20 feet be retroactively addressed.

Confirmation of this interpretation was addressed at the April 10, 2024 meeting of The Jefferson County Fire Chiefs and includes all Fire Departments in Jefferson County.

A handwritten signature in black ink, appearing to read "B. S. Meurer", written over a horizontal line.

Brian S. Meurer, President  
Jamie Hundley, Vice President  
Brad Silveria, 2nd Vice  
Chris Noe, Secretary