

From: Mike Allendorf mike.allendorf@okolonafire.org
Subject: RE: Plan Review
Date: July 10, 2017 at 1:34 PM
To: Matt Gullo matt.gullo@koverthawkins.com

MA

Matt,

Thanks for the quick reply on my questions. Based off those answers please accept this email as the Okolona Fire Departments approval for the gate that was shown on a PDF drawing in a blue box from your original email. The gate is 28' in width which is more than adequate to get emergency equipment through that gate if needed. With regards to the locking device on the gate typical padlock and chain will suffice for our access or if UPS chooses they can purchase a KnoxBox brand padlock and if UPS wants to do this they can contact us and we can tell them the type of padlock required.

If you have any questions or need further information please feel free to contact me.

Thanks,

MIke Allendorf
Mike Allendorf
Fire Marshal
Okolona Fire Department

From: Matt Gullo [mailto:matt.gullo@koverthawkins.com]
Sent: Monday, July 10, 2017 1:28 PM
To: Mike Allendorf <mike.allendorf@okolonafire.org>
Subject: Re: Plan Review

Mike,
There will not be a middle section for the gate, it will be open the entire length. The late will be locked but I am going to say they can provide a Knox Box for fire. The fence will only be a chain link with typical pad lock, so you cutting is the other option. There will be more then one entry/exit on site too.

Thanks much!

On Jul 10, 2017, at 12:30 PM, Mike Allendorf
<mike.allendorf@okolonafire.org> wrote:

Matt,

Looks like the drive width is 28' across. Is that the same for the gate or will there be a middle section that 14' gates connect too. Also how will the gate be locked? If

only for emergency access only we can see if UPS would purchase a Knox padlock where only FD can access it. Or it can be a chain and padlock they want and we can cut the chain if we need access. Only questions I have for the gate proposal.

Thanks,

MIke Allendorf

MIke Allendorf
Fire Marshal
Okolona Fire Department

From: Matt Gullo [<mailto:matt.gullo@koverthawkins.com>]

Sent: Monday, July 10, 2017 12:03 PM

To: Mike Allendorf <mike.allendorf@okolonafire.org>

Subject: Plan Review

Hi Mike,

I have a comment from metro public works on one of my development plans asking if you could sign off to a proposed gate located along Air Commerce Drive. This is going to be a new UPS warehouse facility and one of the exits onto Air Commerce will be for emergencies only with a gate. I have the plan attached with the gate in question marked. Can you take a look to see if there would be any problems with this proposed gate? Please give me a call if you have questions, thanks much.

Matthew D. Gullo, RLA

CLARB Certified Landscape Architect
Director of Landscape Architecture
and Planning
EMAIL: matt.gullo@koverthawkins.com

Kovert Hawkins Architects

630 Walnut Street
Jeffersonville, IN 47130
direct: 812.913.4616
fax: 812.282.9171

Matthew D. Gullo, RLA

CLARB Certified Landscape Architect
Director of Landscape Architecture
and Planning
EMAIL: matt.gullo@koverthawkins.com

Kovert Hawkins Architects

630 Walnut Street
Jeffersonville, IN 47130
direct: 812.913.4616
fax: 812.282.9171