

St. Germain, Dante

From: Stuber, Elizabeth W.
Sent: Tuesday, July 20, 2021 11:05 AM
To: St. Germain, Dante
Subject: 21-RSUB-0007 Dobson Lane

Dante,

Based on the goetech for this site, I would proposed the following BE for the site.

Due to the significant amount of karst activity on this site. further exploration is needed to determine whether or not Lots 85, 86, 93, 94, 95 and 72 are buildable due to the existence of karst features on the lot near where a building pad would be. The determination must be made before approval of construction plans. Any karst features found on site must be shown on the record plat.

Beth Stuber, PE
Transportation Engineering Supervisor
Planning & Design Services
Department of Develop Louisville
444 South Fifth Street, Suite 300
Louisville, KY 40202
(502) 574-3875
<https://louisvilleky.gov/government/planning-design>

