

Development Review Committee
Staff Report
August 19, 2015



Case No:	15devplan1090
Request:	Detailed District Development Plan
Project Name:	Commerce Crossings Tract 9A Parking Lot
Location:	5121 Commerce Crossings Drive
Owner:	Commerce Crossings LLC
Applicant:	Commerce Crossings LLC
Representative:	Milestone Design Group
Jurisdiction:	Louisville Metro
Council District:	24-Madonna Flood & 13-Vicki Aubrey-Welch
Case Manager:	Julia Williams, AICP, Planner II

REQUEST

- Detailed District Development plan

CASE SUMMARY/BACKGROUND/SITE CONTEXT

Existing Zoning District: PEC
Existing Form District: SW
Existing Use: Vacant
Proposed Use: Parking Lot
Plan Certain Docket #:9-32-97

LAND USE/ZONING DISTRICT/FORM DISTRICT TABLE

	Land Use	Zoning	Form District
<i>Subject Property</i>			
Existing	Vacant	PEC	SW
Proposed	Parking Lot	PEC	SW
<i>Surrounding Properties</i>			
North	Single Family Residential	R-4	SW
South	Office/Industrial	PEC	SW
East	Vacant	PEC	SW
West	Office/Industrial	PEC	SW

PREVIOUS CASES ON SITE

9-32-97-Change in zoning from R-4 to PEC. Approved by the Planning Commission on 7/17/97
B-196-04- Permitted encroachments into the stream buffer. Approved by BOZA 10/18/04

INTERESTED PARTY COMMENTS

None received.

APPLICABLE PLANS AND POLICIES

Cornerstone 2020
Land Development Code

STANDARD OF REVIEW AND STAFF ANALYSIS FOR DDDP

- a. The conservation of natural resources on the property proposed for development, including: trees and other living vegetation, steep slopes, water courses, flood plains, soils, air quality, scenic views, and historic sites;

STAFF: There does not appear to be any environmental constraints or historic resources on the subject site. Tree canopy requirements of the Land Development Code will be provided on the subject site and the stream buffer is provided.

- b. The provisions for safe and efficient vehicular and pedestrian transportation both within the development and the community;

STAFF: Provisions for safe and efficient vehicular and pedestrian transportation within the development and the community has been provided, and Metro Public Works has approved the preliminary development plan.

- c. The provision of sufficient open space (scenic and recreational) to meet the needs of the proposed development;

STAFF: There are no open space requirements with the current proposal.

- d. The provision of adequate drainage facilities on the subject site in order to prevent drainage problems from occurring on the subject site or within the community;

STAFF: The Metropolitan Sewer District has approved the preliminary development plan and will ensure the provisions of adequate drainage facilities on the subject site in order to prevent drainage problems from occurring on the subject site or within the community.

- e. The compatibility of the overall site design (location of buildings, parking lots, screening, landscaping) and land use or uses with the existing and projected future development of the area;

STAFF: The overall site design and land uses are compatible with the existing and future development of the area. Appropriate landscape buffering and screening will be provided to screen adjacent properties and roadways. Buildings and parking lots will meet all required setbacks.

- f. Conformance of the development plan with the Comprehensive Plan and Land Development Code. Revised plan certain development plans shall be evaluated for conformance with the non-residential and mixed-use intent of the form districts and comprehensive plan.

STAFF: The development plan conforms to applicable guidelines and policies of the Comprehensive Plan and to requirements of the Land Development Code.

TECHNICAL REVIEW

1. To meet tree canopy requirements trees must be preserved in a TCPA or WPA. Please label each TCPA with the square footage. Please indicate the extent of the TCPA. It is unclear on the plan where the boundaries for the TCPA are located.
2. Please show and label the 15' LBA along the property lines shared with PEC zoning.
3. Provide the square footage and percentage of existing tree canopy coverage for the site prior to site disturbance. Include this information on the plan in the Tree Canopy Calculation. This is not clear in the canopy requirements.

STAFF CONCLUSIONS

The development plan conforms to applicable guidelines and policies of the Comprehensive Plan and to requirements of the Land Development Code.

Based upon the information in the staff report, the testimony and evidence provided at the public hearing, Development Review Committee must determine if the proposal meets the standards for granting a Detailed District Development Plan established in the Land Development Code.


NOTIFICATION

Date	Purpose of Notice	Recipients
8/6/15	Hearing before DRC	1 st adjoining property owners Speakers at Planning Commission public hearing Subscribers of Council District 24 and 13 Notification of Development Proposals


ATTACHMENTS

1. Zoning Map
2. Aerial Photograph
3. Proposed Binding Elements

1. Zoning Map



2. Aerial Photograph



3. **Proposed Binding Elements**

All binding elements from the approved General Development Plan are applicable to this site, in addition to the following:

1. The development shall be in accordance with the approved district development plan, all applicable sections of the Land Development Code (LDC) and agreed upon binding elements unless amended pursuant to the Land Development Code. Any changes/additions/alterations of any binding element(s) shall be submitted to the Planning Commission or the Planning Commission's designee for review and approval; any changes/additions/alterations not so referred shall not be valid.
2. No outdoor advertising signs, small freestanding signs, pennants, balloons, or banners shall be permitted on the site.
3. Construction fencing shall be erected when off-site trees or tree canopy exists within 3' of a common property line. Fencing shall be in place prior to any grading or construction to protect the existing root systems from compaction. The fencing shall enclose the entire area beneath the tree canopy and shall remain in place until all construction is completed. No parking, material storage or construction activities are permitted within the protected area.
4. Before any permit (including but not limited to building, parking lot, change of use, site disturbance, alteration permit or demolition permit) is requested:
 - a. The development plan must receive full construction approval from Develop Louisville, Louisville Metro Public Works and the Metropolitan Sewer District.
 - b. The property owner/developer must obtain approval of a detailed plan for screening (buffering/landscaping) as described in Chapter 10 prior to requesting a building permit. Such plan shall be implemented prior to occupancy of the site and shall be maintained thereafter.
 - c. A Tree Preservation Plan in accordance with Chapter 10 of the LDC shall be reviewed and approved prior to obtaining approval for site disturbance.
5. There shall be no outdoor music (live, piped, radio or amplified) or outdoor entertainment or outdoor PA system audible beyond the property line.
6. The applicant, developer, or property owner shall provide copies of these binding elements to tenants, purchasers, contractors, subcontractors and other parties engaged in development of this site and shall advise them of the content of these binding elements. These binding elements shall run with the land and the owner of the property and occupant of the property shall at all times be responsible for compliance with these binding elements. At all times during development of the site, the applicant and developer, their heirs, successors; and assignees, contractors, subcontractors, and other parties engaged in development of the site, shall be responsible for compliance with these binding elements.