

## Hall, Yvonne

---

**From:** Joe Elstone <JElstone@ferncreekfire.com>  
**Sent:** Friday, July 28, 2017 10:08 AM  
**To:** Hall, Yvonne  
**Subject:** 17DEVPLAN1133

Yvonne-

If the building has a fire alarm system, then it will need a Knox Box. Additional hydrants will not be needed.

Thx

Joseph Elstone  
Fire Marshal  
Fern Creek Fire Protection District  
9409 Old Bardstown Rd  
Louisville, Ky. 40291  
502 239 7075  
502 239 1872 fax  
[www.ferncreekfire.com](http://www.ferncreekfire.com)