

Hall, Yvonne

From: Mark LaFollette <mark.lafollette@shivelyky.gov>
Sent: Wednesday, March 22, 2017 10:11 AM
To: Hall, Yvonne
Subject: Docket No. 17DELPLAN1031

Hello Yvonne Hall of IARC

After review of the property at 1715 Gagel Avenue (FMC Pleasure Ridge Park) by Chief Greg Cambron and myself. They would need to install a second fire hydrant for the property. It would be a double pumper with two 4 inch outlets capable of producing at least 750 gpm. This is due to the distance and difficulty to reach a second hydrant within the required 1000 feet. Also, Shively Fire & Rescue would reserve the right to review all construction plans for this facility. If you have any questions concerning this project please feel free to contact Chief Cambron at (502) 449-5020 or me.

Respectfully

Mark La Follette
Fire Marshal
Shively Fire & Rescue
1800 Park Road
Shively, Kentucky 40216
Office: (502) 449-5045
Email: mark.lafollette@shivelyky.gov

17 Delplan 1031